



INSTALLATION, OPERATION AND MAINTENANCE INSTRUCTIONS

NexLED


Important : Please read these instructions carefully before installing or maintaining this equipment. Good electrical practices should be followed at all times and this data should be used as a guide only.




0.0 Specification and ATEX Declaration – Zone 1 version

Type Of Protection	Ex de (Flameproof, increased safety)
Protection Standards	EN60079-0, EN60079-1, EN60079-7, EN50281-1-1
ATEX Equipment Classification	Group II Category 2 G D
Area Classification	Zone 1 and Zone 21 areas to EN60079-10 and EN50281-3 with installation to EN60079-14 and EN 50281-1-2 - Gas Groups IIA, IIB and IIC
Certificate	EC Type Examination Certificate Baseefa04ATEX0245
Equipment Coding	 II 2 G Ex de IIC T4 -45°C < Ta < 55°C II 2 D T100°C
Ingress Protection	IP66 and IP67 to BS EN 60529

0.1 Specification and ATEX Declaration – Zone 2 version

Type Of Protection	Ex nAC (Non-sparking)
Protection Standards	EN60079-0, EN60079-15, EN50281-1-1
ATEX Equipment Classification	Group II Category 3 G D
Area Classification	Zone 2 and Zone 22 areas to EN60079-10 and EN50281-3 with installation to EN60079-14 and EN 50281-1-2
Certificate	EC Type Examination Certificate Baseefa04ATEX0244
Equipment Coding	 II 3 G Ex nAC II T5 -45°C < Ta < 55°C II 3 G Ex nAC II T6 -45°C < Ta < 40°C II 3 D T100°C
Ingress Protection	IP66 and IP67 to BS EN 60529
Laser safety class	Class 1 LED product

CE Mark  The CE marking of this product applies to 94/9/EC "The Electrical Equipment (Safety) Regulations 1994", "The Electromagnetic Compatibility Regulations 1992" and the "Equipment and Protective Systems intended for use in Explosive Atmospheres Regulations 1996". [This legislation is the equivalent in UK law of EC directives 73/23EEC, 89/336/EEC and 94/9/EC, respectively].

ATEX Declaration The Equipment as described and identified in these instructions is declared to meet the provisions of the ATEX directive by reason of the EC Type Examination denoted based on the harmonised standards listed above.
I MacLeod Engineering Manager Reference: D03/06-00 dated 30-8-4

1.0 Introduction

The Chalmit NexLED brings to hazardous areas the very latest in lighting technology. It is a compact light source that uses ultra bright light emitting diodes to provide light from mains power. The LED's are maintenance free and last up to 50000 hours. They are housed in an impact and corrosion resistant marine grade aluminium enclosure with a toughened glass lens. Control gear is electronic with regulated lamp output. The lamps, work equally well at very low temperatures as they do at high and produce a product with very low overall power consumption. The LED's also emit no ultra-violet light and no forward heat.

The NexLED is a class 1 LED product.

The product is available with 2-8 lamps or as an exit sign version with which a self adhesive label kit is used.

2.0 Storage

Luminaires are to be stored in cool dry conditions preventing ingress of moisture and condensation.

3.0 Installation and Safety

3.1 General

There are no health hazards associated with this product whilst in normal use. However, care should be exercised during the following operations. Installation should be carried out in accordance with *BS EN 60079-14* or the local hazardous area code of practice, whichever is appropriate, and fitting of specified insulating material to be adhered to where a specific fire resistance rating is required. In the UK the requirements of the '*Health and Safety at Work Act*' must be met.

Handling and electrical work associated with this product to be in accordance with *the 'Manual Handling Operations Regulations'* and '*Electricity at Work Regulations, 1989*'. Your attention is drawn to the paragraphs (i) 'Electrical Supplies', (ii) 'Electrical Fault Finding and Replacement' and (iii) 'Inspection and Maintenance'.

The luminaires are class 1 and should be effectively earthed.

Certification details on the rating plate must be verified against the application requirements before installation.

The information in this leaflet is correct at the time of publication. The company reserves the right to make specification changes as required.

3.1.1 Use in Combustible Dust Atmospheres

Where the equipment is used in ignitable dust atmospheres reference must be made to the selection and installation standards in order that the equipment is used correctly. In particular this applies to the de-rating of surface temperature for use where dust clouds may be present. Dust layers should not be allowed to accumulate on the surface and good housekeeping is required for safe operation. Dust in layers has the potential to form ignitable clouds and to burn at lower temperatures.

The European standard EN 50281-1-2 also gives details of selection, installation and maintenance.

3.1.2 Hybrid Mixtures – Gas and Dust

Where hybrid mixtures exist as defined in EN 1127 as a potentially explosive atmosphere, consideration should be given to verifying that the maximum surface temperature of the luminaire is below the ignition temperature of the hybrid mixture.

3.2 Tools

No 1/2 Philips/Pozidriv screwdrivers
3mm and 5mm flat blade screwdriver
Spanners for installing cable glands.
Pliers, knife, wire strippers/cutters.

3.3 Electrical Supplies

The standard unit is rated for a nominal 220V-254V AC 50Hz or 60Hz. A maximum voltage variation of +6%/-6% on the nominal is expected. (The safety limit for T rating is +10%). Equipment must not be operated outside of the rated voltage of the control gear. The lamp supply is regulated therefore the light output over the supply range is constant.

3.4 Lamps

This product is fitted with LED lamps that last up to 50000 hours. Therefore in many applications re-lamping will be unnecessary. If re-lamping is required ensure mains supplies are isolated before commencing work. Remove the front cover by unscrewing the 4 screws at each corner. Then unscrew the 4 lampholder screws and the lampholder will be released. Disconnect the lampholder terminals/wiring plug and unclip the plastic retainer strap. Assembly is the reverse of dis-assembly ensuring the gasket/glass mating surfaces are clean and cables are not trapped. As the lamps are non standard please contact Chalmit Lighting if replacements are required.

3.5 Mounting

Luminaires should be installed where access for maintenance is practical and in accordance with any lighting design information provided for the installation. Mounting is by 4 holes in the base of the body casting external to the gasket. These should be secured with lock washers or self-locking nuts and bolts and are accessed by removing the front cover. Any mounting attitude may be used.

3.6 Cabling and Cable Glands

3.6.1 Cables

The maximum conductor size is 6mm². Internal earth point is provided next to the main terminal block. 300/500V cable ratings are adequate and no special internal construction is necessary. The standard looping cable size is up to 6mm². The selection of cable size must be suitable for the fuse rating. Terminals are supplied with suitability for looping and through wiring is possible using the tapped cable entry at the opposite end of the enclosure. Where through wiring or looping is used the maximum current is 16A. Terminals are accessed by removing the front cover and lampholder. Maximum cable temperature rise is 20°C above ambient.

3.6.2 Cable Glands

The installer and user must take responsibility for the selection of cables, cable glands and seals. Three tapped cable entries are provided, two with a plug and seal suitable for permanent use, the other with a travelling plug not suitable for use in service. Sealing plugs must be similarly rated and a tool must be used for their removal. Cable entries are M20x1.5.

3.6.2.1 For installation in Zone 1 hazardous areas

The product is certified for ATEX and to comply with the certification for installation and use within the EU, cable glands and sealing plugs must have ATEX component approval or be certified to EN 50014 or EN60079-0.

For installation outside the EU, suitable cable glands in accordance with EN 50014 or IEC 60079-0 will meet the technical requirements.

The cable and gland assembly when installed must maintain a minimum of IP54 rating. The cable gland must withstand an impact value of 7Nm where the risk of mechanical damage is high or 4Nm where the risk of mechanical damage is low.

The cable glands must be suitable for the application. Plastic cable glands must be Ex certified. Where brass cable glands are used in a corrosive environment, cadmium or nickel plating should be used. Where the cable is not reliably clamped externally to the apparatus, the cable gland must clamp the cable against a pull in Newtons of 20 x the cable OD in mm for non-armoured cable and 80 x the cable OD for armoured cable.

3.6.2.2 For installation in Zone 2 hazardous areas

Cable glands for entry into Ex enclosures when fitted with any gland to body sealing method and supply cable, must reliably maintain the IP rating of the enclosure with a minimum value of IP54 or IP6X for conductive dust. Sealing plugs for unused entries should be similarly rated and fitted.

3.7 Cable Connection

The conductors should be bared back so that they make full contact in the terminals, but the bare conductor should not be more than 1mm beyond the terminal. The core must be identified by polarity and connected in accordance with the terminal markings. Before re-fitting the cover, a final check on the correctness of

connections should be made. Mains terminal blocks are marked L and N. Earth connection is made to the earth point alongside the terminals.

The method of insulation testing is to connect live and neutral together and test between this point and earth to prevent the risk of damage to the electronic control gear.

3.8 Exit Sign Version

To apply the exit label remove the glass from the front cover the unscrewing the two retaining lugs. The label must be carefully applied to the outside surface of the glass avoiding bubbles underneath the label. The illuminated height of the label is 140mm with a maximum visible distance of 28M as defined by EN1838.

3.9 Inspection and Maintenance

Visual inspection should be carried out at a minimum of 12 monthly intervals and more frequently if conditions are severe, refer to *BS EN 60079-17*.

4.0 Electrical Fault Finding and Replacement

Any fault finding must be done by a competent electrician with the luminaire isolated and, if carried out with the luminaire in place, under a permit to work. Fault finding is by substitution with known good components.

Routine Maintenance

Visual tests and checks should be carried out at intervals described by the appropriate regulations, EN 60079-17, and should include the following:

Check that the lamps are working.

Check for mechanical damage/corrosion.

Check for loose connections including earthing.

Check for undue accumulations of dust or dirt.

Verification of tightness of fixing, glands, blanking plugs etc.

Check for unauthorised modifications.

Check condition of enclosure gasket and fastenings.

Check for any accumulation of moisture.

Periodic inspection of the enclosure seal should be carried out to ensure that the seal is sound.

If the luminaire has been subject to abnormal conditions, for example, severe mechanical impact or chemical spillage, it must be de-energised until it has been inspected by an authorised and competent person. If in doubt, the unit should be returned to Chalmit for examination and, if necessary, replacement.

Before re-assembling, all connections should be checked and any damaged cable replaced.

5.0 Fuse and MCB Ratings

Current consumption of an 8 lamp unit is 50mA and for a 2 lamp unit 25mA. It is recommended that for selection of MCB's users should consult the MCB manufacturer. MCB ratings can vary depending on the manufacturer and type and the size of the installation, i.e. impedance of conductors, however type 'C' breakers are usually suitable. The electronic control gear has an inrush current of 2A for 500µs on 230V. These figures are worst case with low resistance connections with short cables and low impedance supplies.

6.0 Disposal of Material

The unit is mainly made from incombustible materials. The control gear contains plastic resin and electronic components. All electrical components may give off noxious fumes if incinerated. Take care to render these fumes harmless or avoid inhalation. Any local regulations concerning disposal must be complied with.

Chalmit Lighting 388 Hillington Road, Glasgow G52 4BL, Scotland
A Division of Hubbell Limited

Telephone : +44 (0)141 882 5555
Fax : +44 (0)141 883 3704
Email : info@chalmit.com
Website : www.chalmit.com

Registered Office Ronald Close, Chantry Avenue
Kempston, Bedford. MK42 7RR.

Registered No. 669157

Note Chalmit Lighting reserve the right to amend characteristics of our products and all data is for guidance only.



Chalmit Lighting is a leading supplier of Hazardous Area and Marine Lighting products.